



Smart Temp SMT-770 Chameleon

- SW 1 = ON
- SW 2 = ON
- SW 3 = ON
- SW 4 = ON
- Sw 5 = ON
- Sw 6 = Customer Preference
- SW 7 = Off
- Sw8 = Customer Preference

ALL CARE AND DILIGENCE HAS BEEN TAKEN IN THE PREPARATION OF THIS INTERFACE DIAGRAM. **SMART TEMP AUSTRALIA PTY LTD** WILL ONLY BE RESPONSIBLE FOR DAMAGE CAUSED TO THE SMART TEMP PRODUCT, AND ONLY IF IT HAD BEEN CORRECTLY APPLIED IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS. IT IS THE DEALER / CONTRACTORS SOLE RESPONSIBILITY TO ENSURE CORRECT OPERATION OF THE MAJOR EQUIPMENT IS MAINTAINED.

		<h2>Installation Drawing</h2>	
<b>Drawing Revision History</b>			Drawing Name
			SMT-770 Chameleon & EC-02
			0-10V Valves
<small>All care has been taken in the preparation of this drawing however Smart Temp Australia accept no responsibility for damage that may be caused by using this information. This is a guide only.</small>			
22-03-2011	REV 1.0	By: John K	
Unit 20, 1488 Ferntree Gully Road Knoxfield Vic 3180			
		Ph: (03) 9763 0094	www.themostat.com.au
		Fax: (03) 9763 0098	