







SW 1= ON
SW 2 = ON
SW 3 = OFF
SW 4 = ON
Sw 5 = OFF
Sw 6 = Customer Preference
SW 7 = Off
Sw8 = Customer Preference









Temperzone ISD 135K to 230K

Smart Temp Australia

Installation Drawing

Drawing Revision History		
12-10-2026	John K	V1.5

Drawing Name

SMT-770 wired to a Temperzone ISD 135K - 230K with an Sp6+ Interface & SPSM 2 wire module

All care has been taken in the preparation of this drawing however Smart Temp Australia accept no responsibility for damage that may be caused by using this information. This is a guide only.

U20, 1488 Ferntree Gully rd Knoxfield Vic 3180
Ph:(03) 9763 0094
WWW..thermostat.com.au