




Set inspire Modbus setting to -

Protocol - IntesisBox
 Address - 1
 Baudrate - 9600
 Parity - None
 Date Bits 8
 Stop Bits 2



24V Supply



Set Inspire Dip Switches 1, 2 & 3 ON

