







All Switches OFF



Smart Temp SMT-770 Chameleon

- SW 1 = ON
- SW 2 = ON
- SW 3 = ON
- SW 4 = ON
- Sw 5 = ON
- Sw 6 = Customer Preference
- SW 7 = Off
- Sw8 = Customer Preference

ALL CARE AND DILIGENCE HAS BEEN TAKEN IN THE PREPARATION OF THIS INTERFACE DIAGRAM. **SMART TEMP AUSTRALIA PTY LTD** WILL ONLY BE RESPONSIBLE FOR DAMAGE CAUSED TO THE SMART TEMP PRODUCT, AND ONLY IF IT HAD BEEN CORRECTLY APPLIED IN ACCORDANCE WITH THE MANUFACTURES INSTRUCTIONS. IT IS THE DEALER / CONTRACTORS SOLE RESPONSIBILITY TO ENSURE CORRECT OPERATION OF THE MAJOR EQUIPMENT IS MAINTAINED.

| | | | |
|--|---------|---|--|
| | | <h2>Installation Drawing</h2> | |
| Drawing Revision History | | | Drawing Name |
| | | | Typical 240V Heat Pump Unit with SMT-770 Chameleon & EC-02 |
| | | | <small>All care has been taken in the preparation of this drawing however Smart Temp Australia accept no responsibility for damage that may be caused by using this information. This is a guide only.</small> |
| 24-01-2012 | REV 1.0 | By: John K | |
| Unit 20, 1488 Ferntree Gully Road Knoxfield Vic 3180 | | | |
| | | Ph: (03) 9763 0094 Fax: (03) 9763 0098 | www.themostat.com.au |