


Daikin UATY 15,18,21 KY19

- Daikin UATY 15,18,21 KY19 Connections**
- P1 - Neutral
 - P2 - Active to Thermostat
 - P17 - Reversing Valve
 - P6 - On/Off Fan Interlock
 - P7 - Safety Circuit Comp. interlock
 - P13 - Comp Run Signal 1st Stage Heat
 - P11- Comp Run Signal 1st Stage Cool
 - P8 - Comp Run Signal 2nd Stage Cool
 - P15 - Comp run Signal 2nd Stage Heat

Normal when ON

A B



- Switches**
- 1= OFF 5= ON
 - 2= ON 6= ON (On = Prog. Thermostat)
 - 3= OFF 7= OFF
 - 4= ON 8= ON

Switch in Position A

Installation Drawing

Drawing Revision History		Drawing Name	
		DaikinUATY15,18,21 SMT-700 Elegance	
Rev A	By John K	28-08-2007	

All care has been taken in the preparation of this drawing however Smart Temp Australia accepts no responsibility for damage that may be caused by using this information. This is a guide only.

Ph (03) 9763 0094 Fax (03) 9763 0098 www.thermostat.com.au

Unit 20, 1488 Ferntree Gully Rd Knoxfield Vic 3180